



Number	25GR0240/00	Replaces	--
Issue date	30-07-2025	Contract number	E 8090
Due date	30-07-2035	Module	B (Type testing)
Report number	P000489807	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DQ3807		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **condensing boilers**, model(s):

**MicraCom Condens 24-AS/2 (H-ES),
MicraCom Condens 28-AS/2 (H-ES)**

Manufacturer

**Saunier Duval Dicoso S.A.
Polígono Industrial Ugaldeguren 3 parcela 22
48170 Zamudio (Vizcaya)
Spain**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-2-1:2022+A1:2023 and EN 15502-1:2021+A1:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Wilmsdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number 25GR0240/00 Replaces -

Issue date 30-07-2025 Contract number E 8090

Due date 30-07-2035 Module B (Type testing)

Report number P000489807 Scope (EU) 2016/426 (9 March 2016)

PIN 0063DQ3807 Page 1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
SAUNIER DUVAL DICOSA S.A

Model(s):

Model name	Heat input	
	CH (kW – Hi)	DHW (kW – Hi)
MicraCom Condens 24-AS/2 (H-ES)	3.6 – 18.8	3.6 - 24
MicraCom Condens 28-AS/2 (H-ES)	4.2 – 24.5	4.2 – 28

Model name	Appliance categories		Countries
MicraCom Condens 24-AS/2 (H-ES)	II _{2H3P}	G20 – 20 mbar	Spain
MicraCom Condens 28-AS/2 (H-ES)		G31 – 37 mbar	

Model name	Appliance types	Flue installation manuals (use latest version)
MicraCom Condens 24-AS/2 (H-ES)	B ₃₃ , B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	8000038181
MicraCom Condens 28-AS/2 (H-ES)		

Remarks:

--